

SOLICITATION AMENDMENT

ARIZONA
DEPARTMENT OF CORRECTIONS
1601 W. JEFFERSON, MAIL CODE 55302
PROCUREMENT SERVICES
PHOENIX, ARIZONA 85007

SOLICITATION NO. ADOC12-00001388 / ADC No. 120088DC
AMENDMENT NO. 2

Contract Officer: Karen D. Ingram

SOLICITATION DUE DATE: March 13, 2012

SIGNED COPY OF THIS AMENDMENT MUST BE RETURNED WITH YOUR BID SOLICITATION.
THIS SOLICITATION IS AMENDED AS FOLLOWS:

RFP NO. ADOC12-00001388 / ADC No. 120088DC 2000 Medium Security Prison Beds

The last day for submitting questions to the Department shall be February 29, 2012, 3:00P.M., M.S.T.

Questions have been submitted by a vendor and the Department has provided the following responses

Questions submitted on February 23, 2012

1. The Physical Plant Standards do not consistently differentiate between 500 bed and 1,000 bed units. Some space requirements are based on a number per inmate while others are an overall minimum size. Can the proposer reduce the area requirements for:

1. Contact Visitation - Reduce from 4,000 SF to 2,000 SF and reduce outdoor visiting area from 500 to 250 SF? 2. Vocational Education 3. Industries 4. Property and Mail – Reduce from 1,000 SF minimum to 500 SF? 5. Library – 1,000 SF minimum to 500 SF? 6. Dental Services – 3 chairs per 1,000 inmates reduced to 2 chairs for 500? 7. Commissary – 960 SF minimum reduced to 480 SF? 8. Work Based Education – Minimum of 10,000 SF for work based educational areas and a minimum of 10,000 SF for ACI Industrial areas reduced to 5,000 SF each.

Answer: The Departments Physical Plant Standards apply to any facility being offered. Please also refer to section 1.1.4.5 in the introduction.

2. How far apart 1,000 bed units need to be in a complex

Answer: There needs to be 100' separation between perimeter fences for each prison unit.

SOLICITATION AMENDMENT

ARIZONA
DEPARTMENT OF CORRECTIONS
1601 W. JEFFERSON, MAIL CODE 55302
PROCUREMENT SERVICES
PHOENIX, ARIZONA 85007

SOLICITATION NO. ADOC12-00001388 / ADC No. 120088DC
AMENDMENT NO. 2

Contract Officer: Karen D. Ingram

SOLICITATION DUE DATE: March 13, 2012

SIGNED COPY OF THIS AMENDMENT MUST BE RETURNED WITH YOUR BID SOLICITATION.
THIS SOLICITATION IS AMENDED AS FOLLOWS:

3. How will the Housing control room be use and the Officer assigned to the control in an inmate housing area allowed or expected to come out of the control to perform security inside the housing area or is a rover expected or intended to preform that function?

Answer: Control Rooms in Medium Custody facilities are secure stationary posts. Officers assigned to Control Rooms are to remain at that assigned post and shall not be used collaterally to perform roving security functions.

ALL OTHER PROVISIONS OF THE SOLICITATION SHALL REMAIN IN THEIR ENTIRETY

Vendor hereby acknowledges receipt and understanding of above amendment.

The above referenced Solicitation Amendment
Is hereby executed this 24th day of February,
2012 at Phoenix, Arizona.

Signature _____ Date _____

Typed Name and Title _____

Name of Company _____


Denel Pickering Chief Procurement Officer